

Phase 1: Background Air Monitoring Summary for Seattle Iron and Metals Corporation



Prepared for
Seattle Iron & Metals Corporation
601 South Myrtle Street
Seattle, Washington 98108

Prepared by

25570 Rye Canyon Road, Unit J
Valencia, California 91355
Prepared in consultation with Dr. Ranajit Sahu

April 2020

As part of Consent Decree No. 12-01201RSM, T&B Systems conducted Phase 1 “background” air monitoring upwind of the Seattle Iron and Metals Corporation (SIM) facility in Seattle, Washington from May 8, 2019 through August 29, 2019. The monitoring effort was designed to investigate the contribution of particulate concentrations upwind (South to Southwest) of the SIM property. The following summarizes the conduct of the study and presents observations obtained from the collected data.

STUDY DESIGN

In an earlier round of sampling in 2018, a review of wind rose data from the Seattle-Tacoma airport was performed to identify appropriate locations for installing, at the time, two fence-line monitor systems which were operated in 2018 at the SIM facility.¹ For example, **Figure 1** shows a wind rose for the month of May for the area taken from data collected at Seatac. Based on this as well as data collected at the SIM site in 2018 – which are consistent (as would be expected, since average winds collected over long periods of time do not vary significantly), the greatest frequency of winds come from a southwest to south direction. The goal of the Phase 1 2019 monitoring effort was to select three sites that would measure “background” level impacts of particulate matter including total suspended particulate (TSP) and particulate matter (PM) of 2.5 micrometers or less referred to as PM_{2.5} and to conduct sample collection of polychlorinated biphenyl (PCB) and dioxin compounds upwind of the SIM facility. In addition, the Teflon sample filters from each of the TSP samplers were sent at the end of the monitoring period to a laboratory and analyzed for metals. **Figure 2** shows the monitoring locations relative to the SIM facility. The three background monitoring sites are referred to as Heiser, Residential and City. **Table 1** provides the coordinates for each of the monitoring locations.

METHODOLOGY

Table 2 lists the equipment used for the monitoring effort. The core measurements of the study were continuous measurements of TSP and PM_{2.5} concentrations, continuous meteorology at one of the sites and sample media used to collect PCB and dioxin compounds. Thermo Personal Data Ram (pDR) Model 1500 samplers were used for all TSP and PM_{2.5} measurements and SKC pumps were used with PUF media for the collection of PCB and dioxin compounds. Performance specifications of the equipment are presented in **Table 3**.

¹ This sampling is not the subject of or contained in this report.




Figure 1. Seattle-Tacoma Airport Wind Rose (1961-1990)

Table 1. Site Coordinates

City	47.531368° -122.331062°
Heiser	47.517208° -122.323181°
Residential	47.532211° -122.323769°

Table 2. Instrumentation

Measurement	Site(s)	Make/Model	Sampling parameters	Comments
Wind Speed and Direction	Heiser	RM Young Wind Monitor	1-s scans (not recorded but used in the calculations), 5-min, hourly, 24-hour averages, vector and scalar wind calculations	Sensor was located on a tripod with a height of about 4 meters.
Ambient Temperature/Relative Humidity	Heiser	RM Young 41382VC	1-s scans (not recorded but used in the calculations), 5-min, hourly, 24-hour averages	Sensors were housed in a radiation shield located on a tripod at a height of about 2 meters.
Precipitation	Heiser	Texas Electronics TR-525M	1-s scans (not recorded but used in the calculations), 5-min, hourly, 24-hour totals	Sensor was located on a tripod at a height of about 2 meters.
PM (TSP)	Heiser, City & Residential	Thermo pDR-1500 with TSP cyclone	1-s scans (not recorded but used in the calculations), 5-min, hourly, 24-hour concentrations	Sample inlet height of about 2 meters. Nominal sample flow of 2.0 lpm
PM (PM _{2.5})	Heiser, City & Residential	Thermo pDR-1500 with PM _{2.5} cyclone	1-s scans (not recorded but used in the calculations), 5-min, hourly, 24-hour concentrations	Sample inlet height of about 2 meters. Nominal sample flow of 1.5 lpm
PCB/Dioxins	Heiser, City & Residential	SKC Personal Sample Pump with PUF sample media	Approximately 1-week samples were collected over the study period and analyzed by ALS Life Sciences	Sample inlet height of about 2 meters. Nominal sample flow of 1.0 lpm PCBs analyzed using USEPA Method 1668 and dioxins using USEPA Method 8290A
Metals	Heiser, City & Residential	TSP pDR-1500 Teflon sample filters	Sample filters collected PM over the entire study period and analyzed by CHESTER LabNet	Metals analyzed using X-Ray Fluorescence EPA-IO-3.3
Data recording	Heiser, City & Residential	Campbell Scientific CR1000 and CR300	1-s scans and 5-min, hourly and 24-hour averages/totals	
Cellular telemetry	Heiser, City & Residential	Sierra Wireless AirLink Raven XT and Campbell Scientific CELL210		

Table 3. pDR-1500 specifications.

Concentration measurement range (auto-ranging)	0.001 to 400 mg/m ³
Scattering coefficient range	1.5 x 10 ⁻⁶ to 0.6 m ⁻¹ (approx.) @ λ = 880 nm
Precision/repeatability over 30 days (2-sigma)	± 2% of reading or ± 0.005 mg/m ³ , whichever is larger, for 1-second averaging time ± 0.5% of reading or ± 0.0015 mg/m ³ , whichever is larger, for 10-second averaging time ± 0.2% of reading or ± 0.0005 mg/m ³ , whichever is larger, for 60-second averaging time
Accuracy	± 5% of reading (± precision) traceable to SAE Fine Test Dust
Resolution	0.1 µg/m ³
Particle size range of maximum response	Total Suspended Particulate

The pDR sampler uses an optical method to detect particles, providing a continuous measurement of TSP and PM_{2.5} concentrations. While the sampler does not have EPA Federal Reference Method (FRM) or Federal Equivalent Method (FEM) status for the measurement of TSP and PM_{2.5}, studies have shown that readings from the pDR correlate very well with those from FEM or FRM instrumentation, and therefore provide an economical means of measuring TSP and PM_{2.5} concentrations for this type of application.

FIELD OPERATIONS

The Heiser and Residential sites were installed on May 8 and the City site was installed on May 9, 2019, with continuous PM and meteorological measurements starting on these dates. The PCB and dioxin monitoring commenced at each of the sites on June 10, 2019.

The Heiser site was installed at the Heiser Body Company and was powered by AC power using an extension cord with a battery backup. The pDRs and SKC pumps were housed in the CR1000 datalogger enclosure and was attached to the meteorological tripod. The Wind Monitor sensor orientation was verified with a GPS and oriented to true North. The PM sample inlets were attached to the mast with the inlet located about 1.5 meters under the Wind Monitor. Funnels were attached to prevent rain water from entering the sample lines. **Figure 3** shows the installed system at Heiser.

The City site was installed at the South Seattle Hazardous Waste Facility. The pDRs were installed within the CR300 datalogger enclosure which was mounted on a fence post within the facility. The PM sample inlets were attached to the fencepost at a height of approximately 2 meters. The site was powered by AC power using an extension cord with a battery backup. Funnels were attached to prevent rain water from entering the sample lines. **Figure 4** shows the installed system at the City site.

The Residential site was installed at a residence. The pDRs were installed within the CR300 datalogger enclosure which was placed on a table located in the backyard of the home. The PM sample inlets were attached to a small tripod at a height of approximately 2 meters. The site was powered by AC power using an extension cord with a battery backup. Funnels were attached to prevent rain water from entering the sample lines. **Figure 5** shows the installed system at the Residential site.

Quality Control and Data Validation

Weekly checks of the sampling systems were conducted by Floyd Snider personnel during the 10-week sampling period. These checks included the following:

- Visual check that nothing had changed at the site
- Flow check of the pDR and SKC samplers
- Zero check of the pDR response

Over the period of the study, the sites exhibited increased zero baseline responses. The instruments were “re-zeroed” several times over the course of the study period. Additionally, several of the pDR and SKC pump sample flow rates needed to be adjusted. All adjustments were documented on log sheets by Floyd Snider personnel. The site logs can be found at the end of this report.

In addition to the instrument zero and flowrate drift, Floyd Snider personnel were needed to periodically reset the pDR at the sites as communications from the pDR to the datalogger occasionally would fail. Additionally, some of the rental pDR units experienced malfunctions that could not be addressed/repared in the field and needed to be swapped with different rental units. These periods are noted in the site logs.

All data from the sites were uploaded via cellular modem to T&B’s Vista Data Vision web-based data management system, where they were reviewed on at least a once-daily basis for instrument related

problems, as well as any other issues that could influence the achievement of the study goals. In addition, alarm notifications were used to push email and text alert notifications if any problems were detected.



Figure 3. Heiser site monitoring system



Figure 4. City site monitoring system



Figure 5. Residential Site Monitoring System

DATA SUMMARY

Data collected during the study are summarized below:

- **Table 4** provides the 5-min maximum, 60-minute average and maximum and 24-hour maximum concentrations observed at the sites for the study period and includes the data capture percentage. In addition, the net mass total for the entire study period for each of the sites have been included from the analysis of each of the TSP sample filters analyzed by Chester Labnet.
- **Figures 6 – 9** present the 60-minute and 24-hour averaged TSP and PM_{2.5} concentrations from all sites.
- **Figures 10** presents the 5-minute, and 60-minute averaged TSP and PM_{2.5} pollution roses from all sites.
- **Figure 11** presents the wind rose for the study period from the Heiser site and **Figures 12 – 15** present the meteorological hourly average data from the Heiser site.
- The metals results from the TSP Teflon filters analyzed by CHESTER LabNet is provided at the end of this report.
- The PCB/dioxin results analyzed by ALS Life Sciences laboratory will be provided by Floyd Snider.

Table 4. Average and maximum concentrations for the study period

	City Site TSP Concentrations (µg/m ³)	City Site PM _{2.5} Concentrations (µg/m ³)
5-min maximum	265.5	161.3
60-min maximum	170.6	98.8
24-hr maximum	26.5	16.0
Average study concentration	9.9	6.8
TSP Teflon filter net mass total (Chester LabNet filter ID 18-T125)	1,573	
<i>Data Capture</i>	<i>80.7%</i>	<i>90.6%</i>
	Heiser Site TSP Concentrations (µg/m ³) ²	Heiser Site PM _{2.5} Concentrations (µg/m ³)
5-min maximum	542.9	161.3
60-min maximum	46.0	477.9
24-hr maximum	24.1	29.3
Average study concentration	10.2	5.9
TSP Teflon filter net mass total (Chester LabNet filter ID 18-T123)	2,329	
<i>Data Capture</i>	<i>87.5%</i>	<i>78.0%</i>
	Residential Site TSP Concentrations (µg/m ³)	Residential Site PM _{2.5} Concentrations (µg/m ³)
5-min maximum	405.1	371.9
60-min maximum	99.6	71.9
24-hr maximum	29.1	17.8
Average study concentration	10.8	5.8
TSP Teflon filter net mass total (Chester LabNet filter ID 18-T124)	3,299	
<i>Data Capture</i>	<i>99.9%</i>	<i>99.9%</i>

² Review of the data showed that the Heiser TSP sampler would frequently crash when a high spike in concentration was encountered (most notably, during the 4th of July when the PM_{2.5} maximums occurred), affecting the representativeness of the TSP maximums at this site.

Study-long average filter-based TSP concentrations were estimated using sampler flow rates data to calculate the total volume of air drawn by the samplers. Using notes in the station logs to establish assumptions on the operational state of each sampler, the following concentrations were derived for TSP:

- City – 6.5 $\mu\text{g}/\text{m}^3$
- Heiser – 7.2 $\mu\text{g}/\text{m}^3$
- Residential – 10.2 $\mu\text{g}/\text{m}^3$

In reviewing this data, it is important to note that the Residential TSP sampler remained issue-free throughout the study period. This explains the similarity between the filter-based average concentration (10.2 $\mu\text{g}/\text{m}^3$) and the sampler reported average study concentration (10.8 $\mu\text{g}/\text{m}^3$) for this site. In contrast, both the City and Heiser filter-based measurements are impacted by periods of missing data and varying sampler flow rates that introduce uncertainty into the filter measurements, making comparisons less conclusive. Even so, the calculated filter based concentrations are still within about 3 $\mu\text{g}/\text{m}^3$ of the sampler reported average study TSP concentrations presented in Table 4.

TSP - 1-hr Average ($\mu\text{g}/\text{m}^3$)




Figure 6. 1-Hour average TSP concentrations for the study period

PM_{2.5} - 1-hr Average (µg/m³)




Figure 7. 1-Hour average PM_{2.5} concentrations for the study period




Figure 8. 24-hr average TSP concentrations for the study period

PM_{2.5} - 24-hr Average (µg/m³)






Figure 9. 24-hr average PM_{2.5} concentrations for the study period









Figure 10. 5-min and 1-hour average TSP and $PM_{2.5}$ concentration roses for the study period

Wind Rose - as Function of Filter Variable

Calm: 7.5%



%	
0.0	> 20 mph
0.0	15 < 20 mph
0.0	10 < 15 mph
8.0	5 < 10 mph
43.9	2.5 < 5 mph
40.7	1 < 2.5 mph
7.5	< 1 mph

Time Period
12:00:00 AM 5/8/2019 - 12:00:00 AM 8/30/2019

Figure 11. Heiser site wind rose for study period




Figure 12. Heiser site wind speed (red) and direction (blue) for study period




Figure 13. Heiser site ambient temperature for study period




Figure 14. Heiser site relative humidity for study period




Figure 15. Heiser site precipitation for study period

Site Logs

Site CITY

PDR-1500 Checklist - Seattle Iron & Metals

TSP: Black Cyclone

PM2.5: Blue Cyclone

Date/Time:	5/9 11:00	5/15 12:15	5/23 9:31	5/30 11:11	6/15/19	5/14/19 13:00	6/24/19
Samplers intact upon arrival (Y/N)	Y	Y	Y	Y	Y	Y	Y
Samplers filter changed (Y/N)	N	N	N	N	N	Y	N
TSP Flow rate (± 0.05 lpm)	2.0	6.0	2.8	2.0	2.0	1.7	1.6
PM2.5 Flow rate (± 0.05 lpm)	1.5	1.5	1.55	1.5	1.5	1.5	1.5
TSP zero check (≤ 2 ug/m ³)	0	0.0-1.9	0.0-0.3	0.0-0.1	?	5.7	-6.0-5.8
PM2.5 zero check (≤ 2 ug/m ³)	0	0.0	0.0	0.0	?	0.0	0.0
Samplers operating (Y/N)	Y	Y	Y	Y	Y	Y	Y
Site secured (Y/N)	Y	Y	Y	Y	Y	Y	Y

Comments:

5-9-19: INSTALLED SITE

1227 08:30 CW 09:55 11:59

09:51 09:51

5/15/19 PM2.5 showed 0.0 ug/m³ upon arrival; Flow observed at 1.5 lpm; Discussed w/ D Yoho and all systems appear operational. TSP is low and PM2.5 appears to correlate w/ low flow TSP.

5/23/19 TSP Flow @ 1.7 lpm. NOT operational. Called D. Yoho and adjusted flow rate on meter to 2.3 lpm. Flow reads 2.0 lpm after calibration. restarted. Now zero reading 0.0-0.03 ug/m³. All PM10 readings as expected. D Yoho - watch TSP flow to ensure flow not degassing.

6/30/19 all systems operational
 6/5/19 systems operational but could not get site access to open box and read O's when filter put on. Site access typically only available Thursday/Friday. EST to coordinate when special site access on Monday to set up monitoring equip.

Date/Time:	6/24/19 10:10	7/25/19 10:30	7/26/19 10:20	7/11/19 09:40	7/11/19 09:40	7/11/19 09:40	7/11/19 10:30	7/12/19 09:10
Samplers intact upon arrival (Y/N)	Yes	Y	Y	Y	Y	Y	Y	Y
Samplers filter changed (Y/N)	No	N	N	N	N	N	N	N
TSP flow rate (± 0.05 lpm)	1.75	1.7 → 1.95	2.0	2.0	2.0	2.0	1.7 → 2.0	1.8 → see note
PM2.5 flow rate (± 0.05 lpm)	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5
TSP zero check (≤ 2 ug/m3)	0.0	0.0	0.0	1.3-2.8	0.3-2.5	4.0 → 0.0-2.0	0.0	0.0
PM2.5 zero check (≤ 2 ug/m3)	0.0	0.0	0.0	see note	0.0	see note	0.0	0.0
Samplers operating (Y/N)	Y	Y	Y	Y	Y	Y	Y	Y
Site secured (Y/N)	Y	Y	Y	Y	Y	Y	Y	Y

Comments: offsite 10:10 offsite 1335

7/11/19 PM2.5 sampler read 0.0 with no noise for 5 min despite shaking new can + full power about does not pick up PM from resampling fissure. Flow rate is normal. Called D. Yotto he advised we should order new pump and will coordinate that. Engines to get up on next TSP pump working w/no issues

7/11/19 PM2.5 sampler reading 0.0 entire time of visit. Assumed to be operational, just no PM2.5 to read (same as last visit) 7/25/19 PM2.5 sampler screen reading in 200-400 ug/m3 range and reporting on data logger as 1000 ug/m3. Flashed @ 1000 over last several days. Cycled power on PM2.5, data logger power, took out unit batteries, and re-zeroed. Readings still too high. Contacted D. Bush & D. Yotto to have new pump sent. Received TSP and recalibrated flow rate.

7/27/19 TSP flow rate low. Called D. Yotto to discuss. Agreed best to keep flow rate as is w/pump flow rate at 2.8 and readings on extrapolate at 1.8 so as not to max pump. TSP reading 0.0 ug/m3 but does log like generated particulate ok. Replaced PM2.5 pore and bore flow and zero checks in expected range after initial calibration

Site C174

PDR-1500 Checklist - Seattle Iron & Metals

TSP: Black Cyclone
PM2.5: Blue Cyclone

Date/Time:	8/11/19 12:18	8/11/19 12:55	8/15/19 15:30	8/16/19 11:30				
Samplers intact upon arrival (Y/N)	Y	Y	Y	Y				
Samplers filter changed (Y/N)	N	N	See Note	N				
TSP flow rate (± 0.05 lpm)	1.7	1.6	1.5	1.6				
PM2.5 flow rate (± 0.05 lpm)	1.5	1.5	1.5	1.5				
TSP zero check (≤ 2 ug/m ³)	0.1	See note	1.2	1.7				
PM2.5 zero check (≤ 2 ug/m ³)	0.0	G.O	0.0	G.O				
Samplers operating (Y/N)	Y	TSP No; PM2.5: Y	TSP replaced; Y	G.O				
Site secured (Y/N)	Y	Y	Y	Yes				

Comments:

8/11/19 Low TSP flow consistent w/ previous site check on 7/27/19; TSP readings on PDR appear to be w/in previously observed range

8/18/19 TSP Screen reads Conc: $100 \mu\text{g}/\text{m}^3$ TWA: $20.46 \text{ mg}/\text{m}^3$; restarted @ 12:50 after cycling power upon restart TSP reading $\sim 65 \text{ mg}/\text{m}^3$ TWA: $65.97 \text{ mg}/\text{m}^3$; Call to D. Xiao at TAB Systems for next steps and left a message; Unable to zero unit

8/15/19 TSP w/ filter changed when new TSP sampler replaced. Old filter left in old PDR until lab nearby provided filter. Continuation is available - TSP filter will need to be analyzed for metals. Sample removed 8/15/19 15:35. Both samplers operational/working after replacing TSP PDR.

DATE CODE 301B

PDR-1500 Checklist - Seattle Iron & Metals

Site Heisee

TSP: Black Cyclone
PM2.5: Blue Cyclone

Date/Time:	6/25/19 15:15	6/26/19 9:00	7/5/19 11:00	7/11/19 9:20	7/19/19 08:15	7/25/19 11:50	8/1/19 11:37
Samplers intact upon arrival (Y/N)	Y	Y	Y	Y	Y	Y	Y
Samplers filter changed (Y/N)	N	N	N	N	Y	N	N
TSP Flow rate (± 0.05 lpm)	1.05 \rightarrow 2.0	1.9 \rightarrow 2.0	2.05	2.0	2.0	2.0	1.9 \rightarrow 2.0
PM2.5 flow rate (± 0.05 lpm)	1.45	1.5	1.45	1.4 \rightarrow 1.5	1.3 \rightarrow 1.5	1.3 \rightarrow 1.5	1.5
TSP zero check (≤ 2 ug/m ³)	0.0 - 1.3	0.0 - 2.0	0.0	1.0	0.0	0.0	0.0
PM2.5 zero check (≤ 2 ug/m ³)	0.0 - 2.1	0.0 - 1.1	0.0 - 0.0	0.0	2.0 \rightarrow 0.0	0.0	0.0
Samplers operating (Y/N)	Y	Y	N - See below	Y	Y	Y	Y
Site secured (Y/N)	Y	Y	Y	Y	Y	Y	Y

Comments:

6/25/19: TSP Flow rate low, recalibrated from 1.05 LPM to 2.0 LPM
PM2.5 Flow rate low, recalibrated from 1.35 LPM to 1.45 LPM

6/26/19: TSP Flow rate low, recalibrated from 1.9 LPM to 2.0 LPM
PM2.5 Flow rate low, recalibrated from 1.35 LPM to 1.45 LPM

7/5/19: TSP Sampler off upon arrival. Turned back on at 11:00

7/11/19: PM2.5 Flow low, recalibrated from 1.4 \rightarrow 1.5 LPM
7/19/19: TSP sampler off on arrival, turned on @ 8:15. PM2.5 not seeing over steel charging filter. Replaced TSP PDR per D&M decision. New PDR zeros. Both systems on & operational @ 9:05 upon leaving.

7/25/19: PM2.5 sampler flattened, cycled power to pumps. Checked all connections. Cycled power on PM2.5. After checks, readings in normal range and zero drift ok. TSP operating w/no issues

8/1/19: PM 2.5 sampler appeared to flatline. Cycled power to pumps. After restart, PM2.5 readings in normal range and zero check ok

Site HEISER

PDR-1500 Checklist - Seattle Iron & Metals

TSP: Black Cyclone
PM2.5: Blue Cyclone

Date/Time:	5/18 12:00	1/23 5/15	8:51	5/23	5/22 12:10	6/4 8:55	6/19/19 13:05	6/21/19 11:17
Samplers intact upon arrival (Y/N)	Y	Y	Y	Y	Y	Y	Y	Y
Samplers filter changed (Y/N)	N	N	N	N	N	N	N	N
TSP flow rate (± 0.05 lpm)	2.0	2.0	2.0	2.0	2.0	2.0	2.0	1.95
PM2.5 flow rate (± 0.05 lpm)	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.45
TSP zero check (≤ 2 ug/m ³)	0.0	2.4-4.7	0.0	0.0	0.0	0.0	0.0	0.0
PM2.5 zero check (≤ 2 ug/m ³)	0.0	0.6-1.4	0.0	0.0	0.0	0.0	0.0	0.0
Samplers operating (Y/N)	Y	Y	Y	Y	Y	Y	Y	TSP-N Pre-Y
Site secured (Y/N)	Y	Y	Y	Y	Y	Y	Y	Y

Comments:

5/18/19 = LAST TRUCK SITE
 6/19/19 - Arrived on site and observed dust generation associated with street cleaning with blowers to clean pavement for parking striping
 6/21/19 TSP was off upon arrival. TSP monitor repaired to operation at 11:15
 Heiser has begun operation at facility and begun spacing trucks in lot

1150 offsite CW

9:20 offsite CW

12:15 CW

9:05 offsite CW

offsite CW

Site H&S

PDR-1500 Checklist - Seattle Iron & Metals

TSP: Black Cyclone
PM2.5: Blue Cyclone

Date/Time:	8/8/19 12:16	8/15/19 15:00	8/23/19 11:55				
Samplers intact upon arrival (Y/N)	Y	Y	Y				
Samplers filter changed (Y/N)	N	N	N				
TSP flow rate (± 0.05 lpm)	2.0	2.0	2.0				
PM2.5 flow rate (± 0.05 lpm)	1.5	1.5	1.5				
TSP zero check (≤ 2 ug/m ³)	0.0	0.9	0.0				
PM2.5 zero check (≤ 2 ug/m ³)	0.0	0.0	0.0				
Samplers operating (Y/N)	Y	Y	See Notes				
Site secured (Y/N)	Y	Y	Y				

Comments:

8/8/19 - All systems operational
 8/15/19 - Adjusted TSP Flow rate from 1.9 LPM \rightarrow 2.0 LPM
 Rebooted PM2.5 because readings were flatlined prior to arrival. Conc. readings normal & zero ok after reboot
 8/23/19 - Rebooted PM2.5 because readings were flatlined upon arrival. Conc. Readings normal & Zero after reboot

Site RESIDENTIAL

PDR-1500 Checklist - Seattle Iron & Metals

TSP: Black Cyclone
PM2.5: Blue Cyclone

Date/Time:	5/8 14:00	5/8 15:00	5/8 16:03	5/8 17:30	6/5/19 9-13	6/14/19 12-5	8/21/19 12-5
Samplers intact upon arrival (Y/N)	Y	Y	Y	Y	Y	Y	Y
Samplers filter changed (Y/N)	N	N	N	N	N	N	N
TSP flow rate (± 0.05 lpm)	2.0	2.0	2.0	2.0	2.0	2.0	2.0
PM2.5 flow rate (± 0.05 lpm)	1.5	1.4	1.5	1.5	1.5	1.5	1.5
TSP zero check (≤ 2 ug/m3)	0.0	0.0-2.3	0.0-2.6	1.0-3.1	0.0-1.4	0.0-1.3	0.1-1.6
PM2.5 zero check (≤ 2 ug/m3)	0.0	0.0-1.2	0.0-1.1	0.0-1.1	0.0-2.3	0.0-1.3	0.4-1.1
Samplers operating (Y/N)	Y	Y	Y	Y	Y	Y	Y
Site secured (Y/N)	Y	Y	Y	Y	Y	Y	Y

Comments:

12.08 OFFSITE
CW

9.30 OFFSITE/
BY

5/8/19 = INSTALLED SITE

5/23/19 FLOW ON TSP GOOD BUT PM2.5 FLOW LOW. INCREASED PUMP RATE TO 1.7 LPM, NEW FLOW READING @ 1.5 LPM. TSP NOT ZEROED, BOUNCING BETWEEN 1.0-2.0 WITH MOST READINGS 2.1-2.6 ug/m3. PM2.5 ZERO OK, MOST READINGS @ 0.4-1.1 ug/m3

5/20/19 All systems operational

6/14/19 All systems operational

Site Residential

PDR-1500 Checklist - Seattle Iron & Metals

TSP: Black Cyclone
PM2.5: Blue Cyclone

Date/Time:	7/5/19 8:58	7/5/19 11:45	7/11/19 09:00	7/11/19 09:10	7/25/19 19:40	8/1/19 12:50
Samplers intact upon arrival (Y/N)	Y	Y	Y	Y	Y	Y
Samplers filter changed (Y/N)	N	N	N	N	N	N
TSP flow rate (± 0.05 lpm)	1.9	2.0	2.0	2.0	2.0	2.0
PM2.5 flow rate (± 0.05 lpm)	1.95	1.55	1.5	1.7	1.5	1.5
TSP zero check (≤ 2 ug/m ³)	0.4-3.1	0.0-4.0	0.9-2.5	0.1-2.7	0.2-0.6	0.6-1.2
PM2.5 zero check (≤ 2 ug/m ³)	0.0-3.1	0.8-3.0	0.0	0.3-1.5	0.2-0.6	0.0
Samplers operating (Y/N)	Y	Y	Y	Y	Y	Y
Site secured (Y/N)	Y	Y	Y	Y	Y	Y

Comments:

7/11/19 both TSP & PM_{2.5} working as normal/expected
 7/19/19: TSP working as normal/expected. PM_{2.5} higher readings than TSP checked and reduced flow rate. Turn returned machine per photo because conc still higher than TSP. Now zero readings 0.2-0.6 ug/m³
 7/25/19: Spider webs in both TSP and PM_{2.5} inlet. Neither fully zero. Call D photo and see/calibrate both.
 8/1/19: Both Systems operational

Site Yes/Amesford

PDR-1500 Checklist - Seattle Iron & Metals

TSP: Black Cyclone
PM2.5: Blue Cyclone

Date/Time:	8/8/19 1334	8/15/19 1620	8/23/19						
Samplers intact upon arrival (Y/N)	Y	Y	Y						
Samplers filter changed (Y/N)	N	N	Y						
TSP flow rate (± 0.05 lpm)	2.0	2.0	2.0						
PM2.5 flow rate (± 0.05 lpm)	1.5	1.45	1.45						
TSP zero check (≤ 2 ug/m ³)	4.7 0.0	0.9	0.9						
PM2.5 zero check (≤ 2 ug/m ³)	0.0	0.0	0.0						
Samplers operating (Y/N)	Y	Y	Y						
Site secured (Y/N)	Y	Y	Y						

Comments:

8/8/19: TSP will not zero at ≤ 2 ug/m³; Re-Zero unit @ 1400 BK:OK; Restart run @ 1404

Created by: Emily Jones

Reviewed by:

Subject: SET-UP PCB/DIOXIN PUF SAMPLERS

SIM DUST STUDY SITE VISIT 6/10/19

E. JONES Arrived @ Heisee SITE @ 2:15

David Yoho Arrives @ 2:20
All systems intact & operational

WANT flow reading on new PCB/dioxin sampling pump to be ~1Lpm during entire period

Document start & stop dates @ times for all samples - won't be able to see readings on 2/3 of the new pump systems

CAN ADJUST flow w/ screwdriver on front face of pump if flow drops when retrieval to collect sample

Silver surface = correct low flow filter - don't use blue

Take flow readings from Qa row. Qa won't measure flow < 1 Lpm.

Will need to attach & reattach POLY tubing from cone

Filter inserts into poly tubing via wide poly tubing connection

Tape poly tubing to cone and reattach to stand w/ zip ties

Wrap filter in tin foil when collecting sample & place back in sample jar to ship

Write site name on label of glass container & collection date/time

Place on gel pack in insulated shipper & ship to lab

Collect flow sample reading after taking off filter from poly tube exterior to box

Heisee sample started 14:52

Each visit make sure pump inlet tubing still intact

Then calibrate flow if needed
reboot new flow for start of next sample
insert new filter
reattach to post

3:01 secure site & depart @ 3:05

E. JONES & DAVID YOHU arrive to residential site @ 3:15

Property owner notes their family had a boat fire in the last week, will check calendar & send dates/approx timeframe to E. Jones

D. Yoho begins setting up equipment. PUF sampler flow meter will be in the box with power supply.

DIFFICULT TO CALIBRATE flow @ RESIDENTIAL SITE - PUMP IS DIFFERENT THAN AT OTHER 2 SITES. THIS PUMP DOES ALLOW A TOTAL FLOW READING.

Materials:
Zip ties
electrical tape
new filter
new sampling pump
Qa flow electrode
old sample jar

Pump power connection a bit loose so ensure fitting on cold = GOOD FIT

SAMPLE START @ 15:43 PUMP FLOW RATE 1.02 LPM

To turn on/off - call david - but can do it by hitting up * down at same time
needs to be "off hold" to be running.

To cycle through readings use * button - flow on pump = 900ml → 1.02 LPM on reader

15:48 site secured & offsite @ 15:50

E. JONES & DAVID YOHIO ARRIVE @ CITY TRANSFER STATION @ 4:00 / 16:00
MEET JEFF NEUNER FOR ACCESS
ALL SYSTEMS OPERATIONAL & INTACT

PUMP FLOW @ 1.07 LPM SAMPLE START @ 16:00

Secure site @ 16:12 DEPART @ 16:15



SIM PUF Sampling

Site	PUF #	Start Date/Time	Start Flowrate	End Date/Time	End Flowrate	Total Volume	START / END
Heiser	25745104	6/10/19 14:52	1.098 LPM	6/11/19 14:52	0.100 LPM	---	---
Residential	25745102	6/10/19 15:43	1.02 LPM	6/11/19 17:00	0.100 LPM	---	---
City	25745103	6/10/19 16:00	1.07 LPM	6/11/19 13:46	0.100 LPM	---	---
Heiser	25745104	6/11/19 14:20	1.085 LPM	6/20/19 16:23	0 LPM	---	2574 on 153/0000
Heiser	25745102	6/25/19 15:30	1.055 LPM	6/26/19 9:13	1.06 LPM	---	0000/0238
Residential	25745105	6/25/19 16:10	1.000 LPM	6/26/19 13:07	0 LPM	---	0000/0238
Heiser	25745103	6/26/19 9:31	1.06 LPM	7/5/19 11:07	1 LPM	---	0000/9824
City	25745101	6/26/19 16:33	1.1 LPM	7/5/19 12:25	1 LPM	---	0000/0204
Residential	25745100	6/26/19 17:20	1.15 LPM	7/5/19 11:50	1 LPM	---	0000/9824
Heiser	25745110	7/5/19 11:19	1.00 LPM	7/11/19 08:33	1.1 LPM	---	0000/9824
Residential	25745109	7/5/19 12:00	1.00 LPM	7/11/19 09:28	0 LPM	---	0000/1155
City	25745107	7/5/19 12:37	1.00 LPM	7/11/19 09:54	1.0 LPM	---	0000/9401
Heiser	25745105	7/11/19 08:45	1.1 LPM	7/11/19 08:25	1.1 LPM	---	0000/999
Residential	25745106	7/11/19 09:59	1.0 LPM	7/11/19 09:40	0 LPM	---	0000/sample over

Comments:

Callie - Residential - Q: Under Val: 486.0 L 27.2 J: 5:07:25 Min 554. Flow: 800 mL/min
 D: System appears to inductively been bypassed and was not sampling when I worked on site
 Called D. Yain to discuss Sample of 1 liter with 2 liter can baracard
 Heiser meter placed on hold due to no filter after sample collection; Challenger calculator read Q: Under external reference ~1.0
 City meter placed on hold due to no filter after sample collection; Challenger calculator read Q: Under internal reference ~1.0
 6/26/19 CITY - PUMP WAS NOT RUNNING WHEN I ARRIVED. SCREEN READ 0000 SAMPLE OVER. PREVIOUS SAMPLE ON 6/24/19
 6/26/19 RESIDENTIAL - PUMP WAS NOT RUNNING WHEN I ARRIVED. SCREEN READ 0000 AND FLOW AT ~1.1 LPM
 6/26/19 HEISER - PUMP WAS NOT RUNNING WHEN I ARRIVED. SCREEN READ 3643 HOLD AND "LO BATT" PRESSED START
 OF DRAIN WERE STARTED NEW SAMPLE WITH TIME AT 0000 AND FLOW AT 1.2 LPM THAT HAVE BEEN QUINED
 BUTT AND SCREEN TUNED MINUTES UP READ "SAMPLE RUNNING" AND "BATT WITH FLOW AT 1.2 LPM THAT HAVE BEEN QUINED"
 HEISER NO ARRIVAL ISSUES WITH SAMPLE RUNNING AND "LO BATT" WITH FLOW AT 1.2 LPM THAT HAVE BEEN QUINED
 7/15/19 Heiser - No Arrive Issues - Sample Running
 Tested flow Returner & Pressed Start and Pump turned on Returner = 1
 Turned on/off Returner & Pressed Start and Pump turned on Returner = 1
 Residential - Does not appear to be running when I arrived. Hold 1 Batt, 0204 displayed. Removed Filter and
 City - No apparent issues - Sample Running

Heiser 7/11/19 - Yesterday during power check sample time was 0401; today pulled sample @ 1531. Assumed affected by 7/9/19 power out
 Residential's battery issue not resolved, still says to BART/HOLD, pump not running. No AC Adapter to replace battery.
 POC David's recommendation will remove pump and bring to office to resolve w/SLC.

Metals Analysis Results

Location	Lab ID	Analyte	Metals Mass (micrograms)	Metals Concentration (micrograms/m³)
City	18-T125	Copper	3.3	0.037
		Lead	1.0	0.011
		Mercury	0.025	0.00028
		Zinc	3.3	0.037
Heiser	18-T123	Copper	2.3	0.033
		Lead	0.85	0.012
		Mercury	0.025	0.00036
		Zinc	6.3	0.092
Residential	18-T124	Copper	3.2	0.047
		Lead	2.1	0.031
		Mercury	0.0086	0.00013
		Zinc	15.5	0.23

T&B SYSTEMS
PROJECT: SMS

CLIENT # T011
REPORT # 19-438

SUBMITTED BY:
CHESTER LabNet
12242 S.W. GARDEN PLACE
TIGARD, OR 97223
(503)624-2183/FAX (503)624-2653
www.ChesterLab.Net

CHESTER LabNet

12242 SW Garden Place ❖ Tigard, OR 97223-8246 ❖ USA
Telephone 503-624-2183 ❖ Fax 503-624-2653 ❖ www.chesterlab.net

Case Narrative


Date: September 12, 2019

General Information

Client: T&B Systems
Client Number: T011
Report Number: 19-438
Sample Description: 37mm Teflon
Sample Numbers: 18-T123 – 18-T125

Analysis

Analytes: XRF Metals (Na – Pb)
Analytical Protocols: X-Ray Fluorescence: EPA IO-3.3 (June 1999 version)
Analytical Notes: No problems were encountered during the analyses. The results have not been blank corrected.
QA/QC Review: All of the data have been reviewed by the analysts performing the analyses and the project manager. All of the quality control and sample-specific information in this package is complete and meets or exceeds the minimum requirements for acceptability.
Comments: If you have any questions or concerns regarding this analysis, please feel free to contact the project manager.
Disclaimer: This report shall not be reproduced, except in full, without the written approval of the laboratory. The results only represent that of the samples as received into the laboratory.

 9/12/19
Project Manager Date
Paul Duda

Client: T011 - T4B Systems
 Report Number: 19-438

Lab ID: 18-T123
 Filter Lot #: 771415
 Deposit Area: 6.60 cm²

Analyte	µg/filter	percent
Gravimetry		
Net Mass	2,329. ± 10.	
XRF		
Na	55.29 ± 10.73	2.374 ± 0.4609
Mg	25.76 ± 3.260	1.106 ± 0.1400
Al	51.59 ± 5.103	2.215 ± 0.2193
Si	146.4 ± 12.53	6.285 ± 0.5388
P	3.432 ± 0.2891	0.1474 ± 0.0124
S	106.3 ± 8.012	4.562 ± 0.3446
Cl	8.672 ± 0.5425	0.3724 ± 0.0233
K	24.85 ± 1.412	1.067 ± 0.0608
Ca	64.10 ± 3.544	2.752 ± 0.1526
Ti	5.343 ± 0.2680	0.2294 ± 0.0115
V	0.3551 ± 0.0238	0.0152 ± 0.0010
Cr	0.4244 ± 0.0251	0.0182 ± 0.0011
Mn	1.579 ± 0.0805	0.0678 ± 0.0035
Fe	81.44 ± 4.072	3.497 ± 0.1755
* Co	0.0000 ± 0.1056	0.0000 ± 0.0045
Ni	0.2660 ± 0.0139	0.0114 ± 0.0006
Cu	2.336 ± 0.1168	0.1003 ± 0.0050
Zn	6.265 ± 0.3135	0.2690 ± 0.0135
* Ga	0.0000 ± 0.0040	0.0000 ± 0.0002
* Ge	0.0000 ± 0.0033	0.0000 ± 0.0001
As	0.2020 ± 0.0145	0.0087 ± 0.0006
Se	0.2086 ± 0.0106	0.0090 ± 0.0005
Br	0.5702 ± 0.0290	0.0245 ± 0.0013
Rb	0.0568 ± 0.0053	0.0024 ± 0.0002
Sr	0.5636 ± 0.0284	0.0242 ± 0.0012
Y	0.0224 ± 0.0073	0.0010 ± 0.0003
Zr	0.7570 ± 0.0389	0.0325 ± 0.0017
Mo	0.1439 ± 0.0172	0.0062 ± 0.0007
* Pd	0.0000 ± 0.0185	0.0000 ± 0.0008
* Ag	0.0323 ± 0.0185	0.0014 ± 0.0008
* Cd	0.0000 ± 0.0191	0.0000 ± 0.0008
* In	0.0000 ± 0.0211	0.0000 ± 0.0009
Sn	2.496 ± 0.1274	0.1072 ± 0.0055
Sb	0.3927 ± 0.0449	0.0169 ± 0.0019
Ba	3.114 ± 0.2105	0.1337 ± 0.0091
* La	0.0000 ± 0.0535	0.0000 ± 0.0023
Hg	0.0251 ± 0.0079	0.0011 ± 0.0003
Pb	0.8527 ± 0.0442	0.0366 ± 0.0019

* - XRF Concentration is less than three times the uncertainty

Client: T011 - T4B Systems
Report Number: 19-438

Lab ID: 18-T124
Filter Lot #: T71415
Deposit Area: 6.60 cm²

Analyte	pp/filter	percent
Gravimetry		
Net Mass	3,299. ± 10.	
XRF		
* Na	47.23 ± 15.87	1.432 ± 0.4812
Mg	32.89 ± 6.186	0.9969 ± 0.1875
Al	80.19 ± 10.74	2.431 ± 0.3258
Si	224.0 ± 24.63	6.790 ± 0.7469
P	4.277 ± 0.4541	0.1296 ± 0.0138
S	118.3 ± 10.84	3.587 ± 0.3287
Cl	36.00 ± 2.492	1.091 ± 0.0756
K	37.01 ± 2.257	1.122 ± 0.0685
Ca	184.7 ± 10.84	5.600 ± 0.3289
Ti	7.359 ± 0.3689	0.2231 ± 0.0112
V	0.5095 ± 0.0317	0.0154 ± 0.0010
Cr	0.9722 ± 0.0515	0.0295 ± 0.0016
Mn	3.701 ± 0.1861	0.1122 ± 0.0057
Fe	194.5 ± 9.722	5.896 ± 0.2952
* Co	0.0000 ± 0.2468	0.0000 ± 0.0075
Ni	0.4884 ± 0.0251	0.0148 ± 0.0008
Cu	3.233 ± 0.1617	0.0980 ± 0.0049
Zn	15.52 ± 0.7755	0.4703 ± 0.0236
Ga	0.0587 ± 0.0059	0.0018 ± 0.0002
* Ge	0.0000 ± 0.0046	0.0000 ± 0.0001
As	0.3234 ± 0.0224	0.0098 ± 0.0007
Se	0.3227 ± 0.0165	0.0098 ± 0.0005
Br	0.6211 ± 0.0317	0.0188 ± 0.0010
Pb	0.1003 ± 0.0066	0.0030 ± 0.0002
Sr	1.153 ± 0.0581	0.0350 ± 0.0018
Y	0.0409 ± 0.0079	0.0012 ± 0.0002
Zr	0.4699 ± 0.0350	0.0203 ± 0.0011
Mo	0.2033 ± 0.0191	0.0062 ± 0.0006
* Pd	0.0515 ± 0.0191	0.0016 ± 0.0006
* Ag	0.0000 ± 0.0185	0.0000 ± 0.0006
* Cd	0.0000 ± 0.0191	0.0000 ± 0.0006
* In	0.0000 ± 0.0211	0.0000 ± 0.0006
Sn	4.470 ± 0.2251	0.1355 ± 0.0068
Sb	0.2792 ± 0.0442	0.0085 ± 0.0013
Ba	2.632 ± 0.2158	0.0798 ± 0.0065
* La	0.0000 ± 0.0673	0.0000 ± 0.0020
* Hg	0.0086 ± 0.0099	0.0003 ± 0.0003
Pb	2.112 ± 0.1069	0.0640 ± 0.0032

* - XRF Concentration is less than three times the uncertainty

Client: T011 - T&B Systems
Report Number: 19-438

Lab ID: 18-T125
Filter Lot #: T71415
Deposit Area: 6.60 cm²

Analyte	ug/filter	percent
Gravimetry		
Net Mass	1,573. ± 10.	
XRF		
Na	47.61 ± 6.404	3.027 ± 0.4076
Mg	18.86 ± 1.843	1.199 ± 0.1174
Al	29.55 ± 2.403	1.879 ± 0.1532
Si	63.69 ± 4.621	4.049 ± 0.2949
P	2.112 ± 0.1558	0.1343 ± 0.0099
S	106.1 ± 6.956	6.743 ± 0.4443
Cl	2.485 ± 0.1538	0.1580 ± 0.0098
K	22.29 ± 1.216	1.417 ± 0.0779
Ca	49.00 ± 2.624	3.115 ± 0.1680
Ti	2.963 ± 0.1492	0.1884 ± 0.0096
V	0.2983 ± 0.0191	0.0190 ± 0.0012
Cr	0.4191 ± 0.0231	0.0264 ± 0.0015
Mn	0.9834 ± 0.0508	0.0625 ± 0.0033
Fe	39.21 ± 1.960	2.493 ± 0.1256
* Co	0.0000 ± 0.0528	0.0000 ± 0.0034
Ni	0.2963 ± 0.0152	0.0188 ± 0.0010
Cu	3.395 ± 0.1696	0.2158 ± 0.0109
Zn	3.289 ± 0.1643	0.2091 ± 0.0105
Ga	0.0271 ± 0.0040	0.0017 ± 0.0003
* Ge	0.0000 ± 0.0033	0.0000 ± 0.0002
As	0.1478 ± 0.0139	0.0094 ± 0.0009
Se	0.1325 ± 0.0079	0.0097 ± 0.0005
Br	0.5544 ± 0.0284	0.0352 ± 0.0018
Rb	0.0403 ± 0.0046	0.0026 ± 0.0003
Sr	0.6052 ± 0.0304	0.0385 ± 0.0019
Y	0.0462 ± 0.0073	0.0029 ± 0.0005
Zr	0.3934 ± 0.0218	0.0250 ± 0.0014
Mo	0.1102 ± 0.0165	0.0070 ± 0.0010
* Pd	0.0000 ± 0.0185	0.0000 ± 0.0012
* Ag	0.0099 ± 0.0185	0.0006 ± 0.0012
* Cd	0.0323 ± 0.0191	0.0021 ± 0.0012
* In	0.0000 ± 0.0211	0.0000 ± 0.0013
Sn	2.219 ± 0.1135	0.1411 ± 0.0073
Sb	0.2462 ± 0.0363	0.0157 ± 0.0023
Ba	2.062 ± 0.1478	0.1311 ± 0.0094
* La	0.0000 ± 0.0396	0.0000 ± 0.0025
Hg	0.0251 ± 0.0079	0.0016 ± 0.0005
Pb	1.020 ± 0.0521	0.0649 ± 0.0033

* - XRF Concentration is less than three times the uncertainty

CHESTER LabNet

Quant'X 1020 XRF Analytical Quality Assurance Report

Client: T&B Systems
 Report: 19-438
 Analysis Period: September 11, 2019
 Number of Samples: 3

1. Precision Data

Micromatter Multi-elemental Quality Control Standard: 34103

QC Standard Results

Analyte	n	micrograms per square centimeter			c.v.	%E
		Calib.	Meas.	S.D.		
Si	1	7.43	7.24	na	na	-2.59
Ti	1	10.50	10.37	na	na	-1.20
Fe	1	10.90	10.79	na	na	-0.98
Se	1	5.08	5.03	na	na	-0.99
Cd	1	6.49	6.63	na	na	2.10
Pb	1	12.38	12.20	na	na	-1.45

2. Accuracy Data

NIST Standard Reference Materials: SRM 2783

Analyte/ SRM	n	Certified Value($\mu\text{g}/\text{cm}^2$)	Measured Value ($\mu\text{g}/\text{cm}^2$)			% Rec.
			High	Low	Average	
K 2783	4	0.5301	0.4577	0.4430	0.4488 +/- 0.0059	84.7
Ca 2783	4	1.3253	1.0658	1.0398	1.0578 +/- 0.0105	79.8
Ti 2783	4	0.1496	0.1290	0.1220	0.1264 +/- 0.0028	84.5
Fe 2783	4	2.6606	2.6075	2.5745	2.5853 +/- 0.0130	97.2
Cu 2783	4	0.0406	0.0383	0.0362	0.0375 +/- 0.0008	92.4
Zn 2783	4	0.1797	0.1730	0.1710	0.1720 +/- 0.0008	95.7
Pb 2783	4	0.0318	0.0382	0.0315	0.0338 +/- 0.0027	106.3

3. Addendum

Micromatter Certified Reference Materials

CRM	Analytes	Certified Value($\mu\text{g}/\text{cm}^2$)	Measured Value($\mu\text{g}/\text{cm}^2$)	% Rec.
39149	Cr	53.7	52.2	97.3
39150	Cu	49.4	51.1	103.4
39151	Zn, Te	49.9	52.0	104.1
39152	Ga, As	50.9	51.2	100.7
39153	Se, Cd	47.1	49.0	104.1
39154	Pb	47.9	48.8	102.0

NIST: National Institute of Standards and Technology

% Rec: Percent Recovery = (Experimental/Given) x 100

n: Number of Observations

S.D.: Standard Deviation

c.v.: Coefficient of Variation = (S.D./Measured) x 100

% E: Percent Error = [(Measured-Calibrated)/Calibrated] x 100

QUANT'X 1020 REPLICATE REPORT

4.45

Original ID: 18T124

Replicate ID: RT124

Element	Original ug/cm2		Replicate ug/cm2		Difference ug/cm2		RPD	
Na	7.1563	+ 2.4053	7.2967	+ 2.4465	-0.1403	+ 3.4308		
Mg	4.9830	+ 0.9372	4.6723	+ 0.8796	0.3107	+ 1.2853	+ 6.4	+ 26.6
Al	12.1452	+ 1.6283	11.8205	+ 1.5812	0.3247	+ 2.2697	+ 2.7	+ 18.9
Si	33.9350	+ 3.7323	33.6650	+ 3.6915	0.2700	+ 5.2495	+ 0.8	+ 15.5
P	0.6480	+ 0.0688	0.6720	+ 0.0711	-0.0240	+ 0.0990	+ -3.6	+ 15.0
S	17.9288	+ 1.6422	17.9895	+ 1.6434	-0.0607	+ 2.3233	+ -0.3	+ 12.9
Cl	5.4545	+ 0.3776	5.4115	+ 0.3742	0.0430	+ 0.5316	+ 0.8	+ 9.8
K	5.6070	+ 0.3420	5.6690	+ 0.3455	-0.0620	+ 0.4861	+ -1.1	+ 8.6
Ca	27.9915	+ 1.6415	27.7465	+ 1.6263	0.2450	+ 2.3107	+ 0.9	+ 8.3
Ti	1.1152	+ 0.0559	1.0932	+ 0.0548	0.0220	+ 0.0782	+ 2.0	+ 7.1
V	0.0772	+ 0.0048	0.0733	+ 0.0046	0.0039	+ 0.0066	+ 5.2	+ 8.8
Cr	0.1473	+ 0.0078	0.1403	+ 0.0075	0.0070	+ 0.0108	+ 4.9	+ 7.5
Mn	0.5608	+ 0.0282	0.5728	+ 0.0288	-0.0120	+ 0.0404	+ -2.1	+ 7.1
Fe	29.4688	+ 1.4734	29.4808	+ 1.4740	-0.0120	+ 2.0842	+ 0.0	+ 7.1
Co	0.0000	+ 0.0374	0.0000	+ 0.0374	0.0000	+ 0.0529		
Ni	0.0740	+ 0.0038	0.0726	+ 0.0037	0.0014	+ 0.0053	+ 1.9	+ 7.2
Cu	0.4898	+ 0.0245	0.4914	+ 0.0246	-0.0016	+ 0.0347	+ -0.3	+ 7.1
Zn	2.3505	+ 0.1175	2.3450	+ 0.1173	0.0055	+ 0.1660	+ 0.2	+ 7.1
Ga	0.0089	+ 0.0009	0.0077	+ 0.0008	0.0012	+ 0.0012	0 14.4	+ 14.3
Ge	0.0000	+ 0.0007	0.0000	+ 0.0007	0.0000	+ 0.0009		
As	0.0490	+ 0.0034	0.0537	+ 0.0036	-0.0047	+ 0.0049	+ -9.2	+ 9.6
Se	0.0489	+ 0.0025	0.0465	+ 0.0024	0.0024	+ 0.0034	+ 5.0	+ 7.2
Br	0.0941	+ 0.0048	0.0920	+ 0.0046	0.0021	+ 0.0066	+ 2.3	+ 7.1
Rb	0.0152	+ 0.0010	0.0173	+ 0.0011	-0.0021	+ 0.0015	0 -12.9	+ 9.2
Sr	0.1747	+ 0.0088	0.1764	+ 0.0089	-0.0017	+ 0.0125	+ -1.0	+ 7.1
Y	0.0063	+ 0.0012	0.0078	+ 0.0012	-0.0015	+ 0.0017	+ -21.4	+ 24.6
Zr	0.1015	+ 0.0053	0.1012	+ 0.0053	0.0003	+ 0.0075	+ 0.3	+ 7.4
Mo	0.0308	+ 0.0029	0.0297	+ 0.0029	0.0011	+ 0.0041	+ 3.6	+ 13.4
Pd	0.0079	+ 0.0029	0.0004	+ 0.0028	0.0075	+ 0.0040		
Ag	0.0000	+ 0.0028	0.0044	+ 0.0028	-0.0044	+ 0.0040		
Cd	0.0000	+ 0.0029	0.0090	+ 0.0029	-0.0090	+ 0.0041		
In	0.0000	+ 0.0032	0.0075	+ 0.0032	-0.0075	+ 0.0045		
Sn	0.6772	+ 0.0341	0.6372	+ 0.0323	0.0400	+ 0.0469	+ 6.1	+ 7.1
Sb	0.0423	+ 0.0067	0.0564	+ 0.0074	-0.0141	+ 0.0100	0 -28.6	+ 20.3
Ba	0.3988	+ 0.0327	0.4318	+ 0.0335	-0.0330	+ 0.0469	+ -7.9	+ 11.3
La	0.0000	+ 0.0102	0.0000	+ 0.0101	0.0000	+ 0.0143		
Hg	0.0013	+ 0.0015	0.0025	+ 0.0015	-0.0012	+ 0.0021		
Pb	0.3200	+ 0.0162	0.3088	+ 0.0156	0.0112	+ 0.0225	+ 3.6	+ 7.1

RPD: Relative Percent Difference $(X1-X2)/[(X1+X2)/2]*100$. RPD is calculated when original value is greater than three times its uncertainty.

PCB/Dioxin Analysis Results

Sample ID	Sample Date	Total PCBs Mass (picograms)	Total PCBs Concentration (picograms/liter)
CIT-061419	6/14/19	2800 J	0.51
CITY-06282019	6/28/19	890 J	0.15
CITY-20190711-0719	7/19/19	940 J	0.094
CITY-20190719-0725	7/25/19	1400 J	0.15
CITY-20190725-0801	8/1/19	1900 J	0.19
CITY-20190801-0808	8/8/19	1500 J	0.15
CITY-20190808-0815	8/15/19	1600 J	0.16
CITY-20190815-0823	8/23/19	1500 J	0.15
CITY-25745101	7/5/19	1600 J	0.16
CITY-45764407	7/11/19	1200 J	0.15

Sample ID	Sample Date	Dioxin/Furan TEQ Mass (picograms)	Dioxin/Furan TEQ Concentration (picograms/liter)
CIT-061419	6/14/19	0.83 J	0.00015
CITY-06282019	6/28/19	0.81 J	0.00014
CITY-20190711-0719	7/19/19	1.8 J	0.00018
CITY-20190719-0725	7/25/19	2.3 J	0.00026
CITY-20190725-0801	8/1/19	1.0 J	0.00010
CITY-20190801-0808	8/8/19	1.1 J	0.00011
CITY-20190808-0815	8/15/19	1.9 J	0.00019
CITY-20190815-0823	8/23/19	0.95 J	0.000095
CITY-25745101	7/5/19	0.89 J	0.000090
CITY-45764407	7/11/19	2.1 UJ	0.00024

Sample ID	Sample Date	Total PCBs Mass (picograms)	Total PCBs Concentration (picograms/liter)
HEI-061419	6/14/19	3100 J	0.55
HEISER-06282019	6/28/19	570 J	0.14
HEISER-20190711-0719	7/19/19	1100 J	0.13
HEISER-20190719-0725	7/25/19	1100 J	0.12
HEISER-20190725-0801	8/1/19	1200 J	0.12
HEISER-20190801-0808	8/8/19	2100 J	0.21
HEISER-20190808-0815	8/15/19	1900 J	0.19
HEISER-20190815-0823	8/23/19	1600 J	0.16
HEISER-25745103	7/5/19	1400 J	5.9
HEISER-25764410	7/11/19	950 J	0.62

Sample ID	Sample Date	Dioxin/Furan TEQ Mass (picograms)	Dioxin/Furan TEQ Concentration (picograms/liter)
HEI-061419	6/14/19	0.70 J	0.00012
HEISER-06282019	6/28/19	0.74 J	0.00019
HEISER-20190711-0719	7/19/19	1.4 J	0.00017
HEISER-20190719-0725	7/25/19	2.0 U	0.00023
HEISER-20190725-0801	8/1/19	1.7 U	0.00017
HEISER-20190801-0808	8/8/19	1.2 J	0.00012
HEISER-20190808-0815	8/15/19	1.7 U	0.00017
HEISER-20190815-0823	8/23/19	2.1 J	0.00021
HEISER-25745103	7/5/19	0.70 J	0.0029
HEISER-25764410	7/11/19	1.4 UJ	0.00093

Sample ID	Sample Date	Total PCBs Mass (picograms)	Total PCBs Concentration (picograms/liter)
RES-061419	6/14/19	1400 J	0.25
RES-25745100	7/5/19	470 J	2.3
RES-25764409	7/11/19	1100 J	0.91
RESIDENTIAL-06282019	6/28/19	980 J	0.27
RESIDENTIAL-20190713-0719	7/19/19	1000 J	0.12
RESIDENTIAL-20190719-0725	7/25/19	930 J	0.10
RESIDENTIAL-20190725-0801	8/1/19	950 J	0.095
RESIDENTIAL-20190801-0808	8/8/19	2100 J	0.21
RESIDENTIAL-20190808-0815	8/15/19	1900 J	0.19
RESIDENTIAL-20190815-0823	8/23/19	1600 J	0.16

Sample ID	Sample Date	Dioxin/Furan TEQ Mass (picograms)	Dioxin/Furan TEQ Concentration (picograms/liter)
RES-061419	6/14/19	0.64 J	0.00012
RES-25745100	7/5/19	0.75 J	0.0037
RES-25764409	7/11/19	2.0 UJ	0.0017
RESIDENTIAL-06282019	6/28/19	1.1 J	0.00030
RESIDENTIAL-20190713-0719	7/19/19	1.3 U	0.00014
RESIDENTIAL-20190719-0725	7/25/19	2.0 U	0.00023
RESIDENTIAL-20190725-0801	8/1/19	1.5 U	0.00015
RESIDENTIAL-20190801-0808	8/8/19	0.98 J	0.000098
RESIDENTIAL-20190808-0815	8/15/19	0.76 U	0.000076
RESIDENTIAL-20190815-0823	8/23/19	0.93 J	0.000093